

# Energy performance certificate (EPC)

H S B C  
Market Place  
Easingwold  
YORK  
YO61 3AA

Energy rating

**E**

Valid until: **18 April 2027**

Certificate number: **0940-1997-0353-6810-5000**

Property type

A1/A2 Retail and Financial/Professional services

Total floor area


186 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

## Energy efficiency rating for this property

This property's current energy rating is E.



Properties are also given a score. The larger the number, the more carbon dioxide (CO<sub>2</sub>) your property is likely to emit.

## How this property compares to others

Properties similar to this one could have ratings:

If newly built

34 | B

If typical of the existing stock

98 | D

Properties are given a rating from A+ (most efficient) to G (least efficient).

## Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
-------------------	---------------------------

---

Building environment	Air Conditioning
----------------------	------------------

---

Assessment level	3
------------------	---

---

Building emission rate (kgCO <sub>2</sub> /m <sup>2</sup> per year)	93.22
---	-------

---

Primary energy use (kWh/m <sup>2</sup> per year)	551
--	-----

---

---

## Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/9160-4014-0935-0500-8791\)](#).

---

## Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

### Assessor contact details

Assessor's name	George Hudson
Telephone	07817 420 685
Email	<a href="mailto:george@chestnutcs.co.uk">george@chestnutcs.co.uk</a>

### Accreditation scheme contact details

Accreditation scheme	Stroma Certification Ltd
Assessor ID	STRO025473
Telephone	0330 124 9660
Email	<a href="mailto:certification@stroma.com">certification@stroma.com</a>

### Assessment details

Employer	CBRE Ltd
Employer address	10 Paternoster Row London EC4M 7HP
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	18 April 2017
Date of certificate	19 April 2017

---